



PRODUCT PERFORMANCE REPORT

Document ID 1495626352

Issued on May 24th, 2017

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Ventsislav Negentsov**
 Company **Behr Hella Thermocontrol GMBH**
 Project reference **Behr Hella Thermocontrol GMBH**
 Project location **Bulgaria**

PRODUCT IDENTIFICATION

Certification Diploma N° **17.04.002**
 Brand **MIDEA**
 Range **BLANC**
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
 Product reference **BLANC-35 OU/BLANC-35 IU**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	62	dB(A)
Lw1 env	55	dB(A)
Cooling		
Pdesignc	3.42	kW
SEER	6.1	
SEER Class	A++	
Qce	196.0	kWh/y
EER @+35	2.76	
General		
Mounting	wall-mounted	
MPS	230-1-50	
Refr. Line	5	m
Refrigerant	R410A	
Heating		
Pdesignh	2.29	kW
SCOP	4.0	
SCOP Class	A+	
Qhe	801.0	kWh/y
Tbiv	-7	C
Ph @Tbiv	2.03	kW
COP @Tbiv	3.26	
TOL	-15.0	C



PRODUCT PERFORMANCE REPORT

Document ID 1495626352

Issued on May 24th, 2017

FEATURE	VALUE	UNIT
Ph @ TOL	2.11	kW
COP @TOL	2.47	
Ph @+7	3.82	kW
COP @+7	3.15	
Power input in other modes		
Poff	1.0	W
Psb	1.0	W
Pto	30.0	W