SILENT



Notes:
• Can't set POWERFUL and SILENT at the same time.

Clean Operation



Notes :
(1) During CLEAN operation period, heating mode will change to fan mode when HEX temparature is "CLNEVP" or more except force 3 minutes operation.
(2) For multi connections, CLEAN operation is limited to fan mode.

Leave Home



Notes:
Perform Leave Home operation according to the following control contents.
(1) Operation mode : Heating
(2) Temperature set : 10˚C
(3) Temperature setting correction shift : + 『SFTLVHM』
(4) Indoor fan : 『FWH_P』
(5) Outdoor fan speed :
(6) Compressor start control :
(7) Compressor speed :
} Same as Basic Heating operation
(8) Lamp indication : i) Operation lamp : ON
ii) Timer lamp : OFF(Cotinuous operation) ; ON(Day timer operation)

Setting Defrosting Inhibit Period



Notes:
(1) The first inhibit time after operation start is set to DFTIM_FST.
(2) From the second time onwards, the inhibit time is set according to the time required for defrosting.
Reverse cycle operation time ≧ [DEFCOL] : DEFTIM_COL is set.
Reverse cycle operation time < [DEFCOL] : The time corresponding to outdoor temperature is set.